

Accredited lab in
Electrical, Oil, Gas,
Telecommunications,
IT,
Renewable Energy
and
Medical Industries



Energy & Power Industries Laboratories Co.(J.S.)

ISO IEC 17025
Accredited Lab

Inspection Body

Test report L13-60018

Page 1 of 10

LQF-708-02
Review No:06

EPIL TEST REPORT

Project No.: L13-60018

Equipment Under Test: *Transmitter Enclosure*

S/N : 990001
Built Year : 2020
IP : 67
Model/Type : PEK-001

Manufactured by: PARS ELECTRONIC KISH.CO

Applicant: PARS ELECTRONIC KISH.CO

Trade Mark:



Tested According to: IEC 60529 2013 COR1:2019

Reception Date of Sample: 24-Jun-2020 **Testing Date:** 11-Jul -2020

Issue Date: 21-Jul-2020

Test Result: PASSED

No. of pages: 10

Prepared and Tested by:

Test Engineer

H. Montazeri

Verified by: Technical Manager

S. M. Mirfallah

Chief Executive Officer

S. M. Mirsadri



Engineering Deputy of Test and
Inspection

Prof. B. Vahid

Technical **This report should not be reproduced in extracts without written approval by EPIL.**

ISO IEC 17025

Test results pertain to the tested sample only.

Accredited Lab

Not Valid Without Lab Stamp.

Office: Unit 12, No.2, Boujari Sefat Dead-End, Corner of Fariman St., Bozorgmehr St., Vali-Asr Ave., Tehran-Iran

Postal Code: 1416854523 Tel: 021-61971 Fax: 021-66174283

Lab: Kavosh Reaserch City, Supa Blvd., 8th km of karaj-Qazvin Freeway, Iran

Tel: 021-61971 Fax: 021-66954601

info@eevil.com www.eevil.com

Accredited lab in
Electrical, Oil, Gas,
Telecommunications,
IT,
Renewable Energy
and
Medical Industries

ISO IEC 17025
Accredited Lab

Inspection Body

Test report L13-60018

Page 2 of 10

LQF-708-02
Review No:06

CONTENTS

	Page
1 GENERAL INFORMATION.....	3
1.1 Product Information.....	3
1.2 Client Information.....	3
1.3 Test Performed.....	3
1.4 Results of Tests.....	3
2 PERFORMANCE and RESULTS of TESTS.....	4
2.1 Marking.....	4
2.2 IP6X, Test for Protection Against Dust	5
2.3 IP6X, Test for Protection Against Access to Hazardous Parts...	6
2.4 IPX7, Test for Protection Against Water	7
3 FIGURES	8



*This report should not be reproduced in extracts without written approval by EPIL.
Test results pertain to the tested sample only.
Not Valid Without Lab Stamp.*

Accredited lab in
Electrical, Oil, Gas,
Telecommunications,
IT,
Renewable Energy
and
Medical Industries



Energy & Power Industries Laboratories Co.(J.S.)

ISO IEC 17025
Accredited Lab

Inspection Body

Test report L13-60018

Page 3 of 10

LQF-708-02
Review No:06

1. GENERAL INFORMATION

1.1 Product Information

Equipment Under Test : Transmitter Enclosure
S/N : 990001
Normative Document : IEC 60529 2013 COR1:2019

1.2 Client Information

Applicant : PARS ELECTRONIC KISH.CO
Telephone : (+98 21) 22987504-05

1.3 Tests Performed

Marking	PASSED
IP6X, Test for Protection Against Dust	PASSED
IP6X, Test for Protection Against Access to Hazardous Parts	PASSED
IPX7, Test for Protection Against Water	PASSED

1.4 Results of Tests

See Page 4 – 8




Technical Department
ISO IEC 17025
Accredited Lab

*This report should not be reproduced in extracts without written approval by EPIL.
Test results pertain to the tested sample only.
Not Valid Without Lab Stamp.*

2. PERFORMANCE and RESULTS of TESTS

2.1. Marking:



2.1.1 Test data

Location : E.P.I.L.
Date : 11-Jul -2020
Engineer of EPIL : H. Montazeri
Normative Document : IEC 60529-2013 COR1:2019

2.1.2 Procedure of test

Compliance with The requirements of sub clause 10, IEC 60529 for marking shall be specified in the relevant product standard.

2.1.3 Acceptance conditions of test

Compliance with the requirements of sub clause 10 of IEC 60529 had checked by inspection.

2.1.4 Result of test

Test was done according to IEC 60529, sub clause 10 and it passed the test.

✓ **PASSED**



2.2 IP6X, Test for Protection Against Dust

2.2.1 Test data

Location	: E.P.I.L.
Date	: 11-Jul -2020
Engineer of EPIL	: H. Montazeri
Normative Document	: IEC 60529 2013 COR1:2019

2.2.2 Ambient conditions

Ambient Temperature	: 24 °C
Relative Humidity	: 45%
Atmospheric Pressure	: 86.5 kPa

2.2.3 Instrument used for the test

Dust Chamber
Vacuum Pump

2.2.4 Procedure of test


The object test under test is placed in its normal operating position in dust chamber and the powder circulation pump would be in working condition. Talcum powder shall be used.
The pressure inside the enclosure is maintained below the surrounding atmospheric pressure by a vacuum pump. The suction connection made to a hole specially provided for this test. The object of the test is to draw into the enclosure by means of depression. A volume of air 80 times the volume of the sample enclosure tested without exceeding the extraction rate of 60 volumes per hour. In no event, shall the depression exceed 2 kPa (20 mbar).
The talcum powder used shall be able to pass through a square-meshed sieve the nominal wire diameter of which is 50 μ m and the nominal width of a gap between wires is 75 μ m (according to IEC 60529).
The duration of the test was 8 h (According to IEC 60529).

2.2.5 Acceptance conditions of test

The protection is satisfactory if no deposit of dust is observed inside the enclosure at the end of the test.

2.2.6 Result of test

The test was done according to IEC 60529 and it passed the test.



*This report should not be reproduced in extracts without written approval by EPIL.
Test results pertain to the tested sample only.
Not Valid Without Lab Stamp.*

Accredited lab in
Electrical, Oil, Gas,
Telecommunications,
IT,
Renewable Energy
and
Medical Industries



Energy & Power Industries Laboratories Co.(J.S.)

ISO IEC 17025
Accredited Lab

Inspection Body

Test report L13-60018

Page 6 of 10

LQF-708-02
Review No:06

2.3 IP6X, Test for Protection Against Access to Hazardous Parts

2.3.1 Test data

Location : E.P.I.L.
Date : 11-Jul -2020
Engineer of EPIL : H. Montazeri
Normative Document : IEC 60529 2013 COR1:2019

2.3.2 Ambient conditions

Ambient Temperature : 24°C
Relative Humidity : 45%
Atmospheric Pressure : 86.5 kPa

2.3.3 Instrument used for the test

Standard wire 1 – 1.05 mm diameter. (table VI - IEC60529).

2.3.4 Procedure of test

The standard probe is pushed against any openings of the enclosure with the force $1 \pm 10\%N$.


2.3.5 Acceptance conditions of test

The access probe shall not touch the surface of the protected space.

2.3.6 Result of test

Test was done according to IEC 60529 and it passed the test.

✓ **PASSED**



*This report should not be reproduced in extracts without written approval by EPIL.
Test results pertain to the tested sample only.
Not Valid Without Lab Stamp.*

Office: Unit 12, No.2, Boujari Sefat Dead-End, Corner of Fariman St., Bozorgmehr St., Vali-Asr Ave., Tehran-Iran
Postal Code: 1416854523 Tel: 021-61971 Fax: 021-66174283
Lab: Kavosh Reaserch City, Supa Blvd., 8th km of karaj-Qazvin Freeway, Iran
Tel: 021-61971 Fax: 021-66954601
info@eepil.com www.eepil.com

2.4 IPX7, Test for Protection Against Water

2.4.1 Test data

Location	: E.P.I.L.
Date	: 12-Jul -2020
Engineer of EPIL	: H. Montazeri
Normative document	: IEC 60529 2013 COR1:2019

2.4.2 Ambient conditions

Ambient Temperature	: 23 °C
Relative Humidity	: 49 %
Atmospheric Pressure	: 86.5 kPa

2.4.3 Instrument used for the test

Immersion Tank

2.4.4 Procedure of test

- The lowest point of enclosures with a height less than 850 mm is located 1000 mm below the surface of the water
- The highest point of enclosures with a height equal to or greater than 850 mm is located 150 mm below the surface of the water
- The duration of the test is 30 min
- The water temperature does not differ from that of the equipment by more than 5K. However, a modified requirement maybe specified in the relevant product standard if the tests are to be made when the equipment is energized and/or its parts in motion.


2.4.5 Acceptance conditions of test

After testing the EUT shall be inspected for ingress of water according to conditions that are specified in IEC 60529.

2.4.6 Result of test

Test was done according to IEC 60529 and it passed the test.

✓ **PASSED**



This report should not be reproduced in extracts without written approval by EPIL.

Test results pertain to the tested sample only.

Not Valid Without Lab Stamp.

Accredited lab in
Electrical, Oil, Gas,
Telecommunications,
IT,
Renewable Energy
and
Medical Industries

ISO IEC 17025
Accredited Lab

Inspection Body

Test report L13-60018

Page 8 of 10

LQF-708-02
Review No:06

3. FIGURES:



Figure 1: EUT

EPIL ✓
Technical Department
ISO IEC 17025
Accredited Lab

This report should not be reproduced in extracts without written approval by EPIL.

Test results pertain to the tested sample only.

Not Valid Without Lab Stamp.

Office: Unit 12, No.2, Boujari Sefat Dead-End, Corner of Fariman St., Bozorgmehr St., Vali-Asr Ave., Tehran-Iran


Postal Code: 1416854523 Tel: 021-61971 Fax: 021-66174283

Lab: Kavosh Reaserch City, Supa Blvd., 8th km of karaj-Qazvin Freeway, Iran

Tel: 021-61971 Fax: 021-66954601

info@eepil.com www.eepil.com

Accredited lab in
Electrical, Oil, Gas,
Telecommunications,
IT,
Renewable Energy
and
Medical Industries



Energy & Power Industries Laboratories Co.(J.S.)

ISO IEC 17025
Accredited Lab

Inspection Body

Test report L13-60018

Page 9 of 10

LQF-708-02
Review No:06




Figure 2: EUT after IP6X



Technical Department
ISO IEC 17025
Accredited Lab

*This report should not be reproduced in extracts without written approval by EPIL.**

Test results pertain to the tested sample only.

Not Valid Without Lab Stamp.

Office: Unit 12, No.2, Boujari Sefat Dead-End, Corner of Fariman St., Bozorgmehr St., Vali-Asr Ave., Tehran-Iran

Postal Code: 1416854523 Tel: 021-61971 Fax: 021-66174283

Lab: Kavosh Reaserch City, Supa Blvd., 8th km of karaj-Qazvin Freeway, Iran

Tel: 021-61971 Fax: 021-66954601

info@eepil.com www.eepil.com



NOTE : Washer was used in the EUT for sealing

Figure 3: EUT after IPX7



*This report should not be reproduced in extracts without written approval by EPIL.
Test results pertain to the tested sample only.
Not Valid Without Lab Stamp.*